

# Confirmation

## LEED

On 14/12/2015, Eurofins Product Testing A/S received a sample of paint with the product name:

### ECOS Eggshell

supplied by

### Imperial Paints LLC

The sample was supplied as being representative of the manufactured product, and it has been tested as paint in accordance with the relevant CDPH 01350, ISO 11890-2 and ASTM D6886 testing standards (See test report no. 392-2015-00421701\_H\_EN and 392-2016-00086001).

**The test results of the tested coating indicate that the product qualifies for LEED v4 and LEED 2009 specifications on VOC emissions and/or VOC content by complying with:**


**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- the requirements of CDPH-IAQ (California Department of Public Health); and a TVOC below 0.5 mg/m<sup>3</sup> in both office and class room.

**VOC content specifications in LEED EQ credit "Low-emitting products":**

- the requirements of SCAQMD rule 1113 (2011)
- the requirements of the EU Decopaint Directive 2004/42/CE

18 March 2016



Thomas Bjerring  
Analytical Service Manager